



Phillips Services (Wales) Ltd
182 Neath Road, Swansea, SA1 2JT
Tel: 01792 653794

PAT Testing results for:

Dinomania Ltd.

Overall results: PASS

Next Test Due: December 2022

assetId	description	lastTestDate	nextTestDate	image	testType	testResult	commentDescription	earthResistance	InsulationResult	leakageResult	wiringResult	earthStatus	InsulationStatus	leakageStatus	wiringStatus	userName	testerType	serialNumber
JF39001	inflexible dipstaur	02-Dec-2021	02-Dec-2022		INSULATION	PASS		N/A	> 19.99	< 0.10	OPEN	N/A	PASS	PASS	N/A	Josh	PT100	43M-2185
JF39002	extension lead - orange cable	02-Dec-2021	02-Dec-2022		LEAKAGE	PASS		0.03	> 19.99	N/A	GOOD	PASS	PASS	N/A	N/A	Josh	PT100	43M-2185
JF39003	speaker	02-Dec-2021	02-Dec-2022		INSULATION	PASS		N/A	> 19.99	0.32	OPEN	N/A	PASS	PASS	N/A	Josh	PT100	43M-2185
JF39004	light	02-Dec-2021	02-Dec-2022		INSULATION	PASS		N/A	> 19.99	0.12	OPEN	N/A	PASS	PASS	N/A	Josh	PT100	43M-2185
JF39005	light	02-Dec-2021	02-Dec-2022		INSULATION	PASS		N/A	> 19.99	0.12	OPEN	N/A	PASS	PASS	N/A	Josh	PT100	43M-2185
JF39006	light	02-Dec-2021	02-Dec-2022		INSULATION	PASS		N/A	> 19.99	0.13	OPEN	N/A	PASS	PASS	N/A	Josh	PT100	43M-2185
JF39007	light	02-Dec-2021	02-Dec-2022		INSULATION	PASS		N/A	> 19.99	< 0.10	OPEN	N/A	PASS	PASS	N/A	Josh	PT100	43M-2185
JF39008	speaker	02-Dec-2021	02-Dec-2022		INSULATION	PASS		N/A	> 19.99	< 0.10	OPEN	N/A	PASS	PASS	N/A	Josh	PT100	43M-2185
JF39009	power lead	02-Dec-2021	02-Dec-2022		INSULATION	PASS		N/A	> 19.99	< 0.10	OPEN	N/A	PASS	PASS	N/A	Josh	PT100	43M-2185
JF39010	projector	02-Dec-2021	02-Dec-2022		INSULATION	PASS		N/A	> 19.99	< 0.10	OPEN	N/A	PASS	PASS	N/A	Josh	PT100	43M-2185
JF39011	projector	02-Dec-2021	02-Dec-2022		INSULATION	PASS		N/A	> 19.99	0.35	OPEN	N/A	PASS	PASS	N/A	Josh	PT100	43M-2185
JF39012	power lead	02-Dec-2021	02-Dec-2022		INSULATION	PASS		N/A	> 19.99	< 0.10	GOOD	N/A	PASS	PASS	N/A	Josh	PT100	43M-2185
JF39013	extension lead	02-Dec-2021	02-Dec-2022		LEAKAGE	PASS		0.05	> 19.99	N/A	GOOD	PASS	PASS	N/A	N/A	Josh	PT100	43M-2185
JF39014	power lead	02-Dec-2021	02-Dec-2022		INSULATION	PASS		N/A	> 19.99	< 0.10	OPEN	N/A	PASS	PASS	N/A	Josh	PT100	43M-2185
JF39015	charger	02-Dec-2021	02-Dec-2022		INSULATION	PASS		0.05	> 19.99	< 0.10	OPEN	N/A	PASS	PASS	N/A	Josh	PT100	43M-2185
JF39016	IEC Lead	02-Dec-2021	02-Dec-2022		LEAKAGE	PASS		N/A	> 19.99	N/A	GOOD	PASS	PASS	N/A	N/A	Josh	PT100	43M-2185
JF39017	IEC Lead	02-Dec-2021	02-Dec-2022		INSULATION	PASS		N/A	> 19.99	< 0.10	OPEN	N/A	PASS	PASS	N/A	Josh	PT100	43M-2185
JF39018	IEC Lead	02-Dec-2021	02-Dec-2022		LEAKAGE	PASS		0.04	> 19.99	N/A	GOOD	PASS	PASS	N/A	N/A	Josh	PT100	43M-2185
JF39019	IEC Lead	02-Dec-2021	02-Dec-2022		LEAKAGE	PASS		0.04	> 19.99	N/A	GOOD	PASS	PASS	N/A	N/A	Josh	PT100	43M-2185
JF39020	IEC Lead	02-Dec-2021	02-Dec-2022		LEAKAGE	PASS		0.05	> 19.99	N/A	GOOD	PASS	PASS	N/A	N/A	Josh	PT100	43M-2185
JF39021	IEC Lead	02-Dec-2021	02-Dec-2022		LEAKAGE	PASS		0.06	> 19.99	N/A	GOOD	PASS	PASS	N/A	N/A	Josh	PT100	43M-2185
JF39022	IEC Lead	02-Dec-2021	02-Dec-2022		LEAKAGE	PASS		0.05	> 19.99	N/A	GOOD	PASS	PASS	N/A	N/A	Josh	PT100	43M-2185
JF39023	IEC Lead	02-Dec-2021	02-Dec-2022		INSULATION	PASS		N/A	> 19.99	< 0.10	OPEN	N/A	PASS	PASS	N/A	Josh	PT100	43M-2185
JF39024	IEC Lead	02-Dec-2021	02-Dec-2022		LEAKAGE	PASS		0.08	> 19.99	N/A	GOOD	PASS	PASS	N/A	N/A	Josh	PT100	43M-2185
JF39025	IEC Lead	02-Dec-2021	02-Dec-2022		LEAKAGE	PASS		0.07	> 19.99	N/A	GOOD	PASS	PASS	N/A	N/A	Josh	PT100	43M-2185
JF39026	power lead	02-Dec-2021	02-Dec-2022		INSULATION	PASS		N/A	> 19.99	< 0.10	OPEN	N/A	PASS	PASS	N/A	Josh	PT100	43M-2185